

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

OCT 11 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford		CHECK ONE <input type="checkbox"/> Town <input checked="" type="checkbox"/> Village <input type="checkbox"/> City			NAME Bridgeport	
2. LOCATION - 1/4 Section SW 1/4 SW 1/4		Section 2	Township 6 N	Range 6 W	3. OWNER AT TIME OF DRILLING Jerry Jones	
OR - Grid or street no.		Street name			ADDRESS R.R. 2 Box 123 A	
AND - If available subdivision name, lot & block no.					POST OFFICE Prairie Du Chien, Wisc.	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 9	SANITARY SEWER C. I. 20 TILE	FLOOR DRAIN C. I. 15 TILE	FOUNDATION DRAIN SEWER CONNECTED None INDEPENDENT	WASTE WATER DRAIN C. I. 15 TILE
CLEAR WATER DRAIN C. I. None	TILE	SEPTIC TANK 36	PRIVY None	SEEPAGE PIT 56	ABSORPTION FIELD None	BARN None
					SILO	ABANDONED WELL None
						SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
None

5. Well is intended to supply water for:
Residence

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	86	6	86	156	Topsoil	Surface	3
						Clay	3	15
						Brn. Sandy Limestone	15	50
						Brn. Limestone & Flint	50	71
						Jordan Sandstone	71	144
						Brn. Limestone	144	156

7. CASING, LINER, CURBING, AND SCREEN				10. TYPE OF DRILLING MACHINE USED			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
6	Steel P.E. 18.97	Surface	86	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water	
8. GROUT OR OTHER SEALING MATERIAL				Well construction completed on 9-24 19 71			
Kind		From (ft.)	To (ft.)				
Neat Cement		Surface	86				

11. MISCELLANEOUS DATA				Well is terminated 20 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade			
Yield test:	4	Hrs. at	11	GPM			
Depth from surface to normal water level	90	ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Depth to water level when pumping	114	ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				

Water sample sent to State Lab. of Hygiene at Madison laboratory on: 9-27 19 71

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Duane Lubbers</i> Duane Lubbers	W.D.#410 Registered Well Driller	COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047
--	-------------------------------------	---

Please do not write in space below

COLIFORM TEST RESULT 281	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------