

JUL 19 1979

1. COUNTY Crawford CHECK (X) ONE:  Town  Village  City Name Bridgeport

2. LOCATION SW 4 Section 6 N Township 6 W Range 6 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (X) ONE Frank Weeks  
 OR - Grid or Street No. Street Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Chase du Chemin

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 130 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other				Seepage Pit	
				Clearwater Dr.	Clearwater Sump						Seepage Bed	
											Seepage Trench	

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	82			
6	82	244			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	40
Sand & Gravel	40	82
May lime	82	155
Sandstone	155	244

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	New Steel T & C / 9.75" A-53 yumpston	Surface	82

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	82

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air  Reverse Rotary

Rotary-w/drilling mud

Well construction completed on 5-8 19 79

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 25 GPM

Depth from surface to normal water level 160 Ft.

Depth of water level when pumping 170 Ft. Stabilized  Yes  No

Well is terminated 8 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on July 10 19 79

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty Registered Well Driller

Complete Mail Address Faherty Drilling Co., Inc.  
1120 Broadway P.O. Box 409  
Platteville, Wisconsin 53818