

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

MAY 10 1979

| | | | | | |
|--|--|--|--|--|--|
| 1. COUNTY <u>Crawford</u> | | CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City | | Name <u>Bridgeport</u> | |
| 2. LOCATION 1/4 Section <u>SW</u> Section <u>10</u> Township <u>6N</u> Range <u>6W</u> | | 3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Kenneth Walters</u> | | ADDRESS <u>RFD</u> | |
| OR - Grid or Street No. Street Name | | POST OFFICE <u>Prairie du Chien, Wis, 53821</u> | | AND - If available subdivision name, lot & block No. | |
| 4. Distance in feet from well to nearest: (Record answer in appropriate block) | | Building <u>16'</u> | | Sanitary Bldg. Drain C.I. Other | |
| | | Sanitary Bldg. Sewer C.I. Other | | Floor Drain Connected To: C.I. Sewer Other Sewer | |
| | | Storm Bldg. Drain C.I. Other | | Storm Bldg. Sewer C.I. Other | |
| Street Sewer San. Storm | | Other Sewers C.I. Other | | Foundation Drain Connected to: Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump | |
| | | | | Sewage Sump C.I. Other | |
| | | | | Clearwater Sump | |
| | | | | Septic Tank, Holding Tank | |
| | | | | Sewage Absorption Unit <u>95'</u> Seepage Pit Seepage Bed Seepage Trench | |
| Privy Pet Waste Pit | | Pit: Nonconforming Existing Well Pump Tank | | Subsurface Pumproom Nonconforming Existing | |
| | | | | Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit | |
| Temporary Manure Stack | | Watertight Liquid Manure Tank | | Solid Manure Storage Structure | |
| | | | | Subsurface Gasoline or Oil Tank Waste Pond or Disposal Unit (Specify Type) Land Other (Give Description) | |
| 5. Well is intended to supply water for: <u>Country home</u> | | 9. FORMATIONS | | | |
| 6. DRILLHOLE | | Dia. (in.) | | From (ft.) To (ft.) | |
| Dia. (in.) From (ft.) To (ft.) | | Dia. (in.) From (ft.) To (ft.) | | Kind | |
| <u>10</u> <u>Surface</u> <u>53</u> | | <u>6</u> <u>53</u> <u>160</u> | | <u>Clay & stone</u> <u>Surface</u> <u>0</u> <u>30</u> | |
| | | | | <u>limestone</u> <u>30</u> <u>92</u> | |
| | | | | <u>hard sandstone</u> <u>92</u> <u>160</u> | |
| 7. CASING, LINER, CURBING AND SCREEN | | Material, Weight, Specification & Method of Assembly | | From (ft.) To (ft.) | |
| Dia. (in.) | | Dia. (in.) | | From (ft.) To (ft.) | |
| <u>6</u> | | <u>new black steel</u> | | <u>0</u> <u>53</u> | |
| | | <u>P.E. 18.97</u> | | <u>Surface</u> | |
| | | <u>A-53</u> | | | |
| | | <u>Kent Steel</u> | | | |
| | | <u>Pitless adaptor</u> | | | |
| 8. GROUT OR OTHER SEALING MATERIAL | | Kind | | From (ft.) To (ft.) | |
| | | <u>Clay</u> | | <u>Surface</u> <u>0</u> <u>8</u> | |
| | | <u>Cement</u> | | <u>8</u> <u>53</u> | |
| 11. MISCELLANEOUS DATA | | Yield Test: <u>2</u> Hrs. at <u>5</u> GPM | | Well construction completed on <u>April 23</u> 19 <u>79</u> | |
| Depth from surface to normal water level <u>80</u> Ft. | | Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below | | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Depth of water level when pumping <u>92</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | |
| Water sample sent to <u>Madison</u> laboratory on <u>May 7</u> - 19 <u>79</u> | | | | | |
| Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side. | | | | | |
| Signature <u>Kenneth Walters</u> Registered Well Driller | | Complete Mail Address <u>Boscobel, Wis.</u> <u>R3 Box 84</u> <u>53805</u> | | | |