

31 1973

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford	CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City	NAME Bridgeport
------------------------------	---	---------------------------

2. LOCATION -	¼ Section SE ¼	Section NW ¼	Section 10	Township 6-N	Range 6-W	3. OWNER AT TIME OF DRILLING Walter Pettit
----------------------	-------------------	-----------------	---------------	-----------------	--------------	--

OR - Grid or street no.	Street name	ADDRESS R.R. 2
-------------------------	-------------	-------------------

AND - If available subdivision name, lot & block no.	POST OFFICE Prairie Du Chien
--	---------------------------------

4. Distance in feet from well to nearest: <small>(Record answer in appropriate block)</small>	BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C.I.	TILE	C.I.	TILE	SEWER CONNECTED INDEPENDENT
	12	24	30	None	None

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	60	None	None	90	200	400	None	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
None

5. Well is intended to supply water for:
New House

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	130	6	130	201	Sandy Clay	Surface	35
						Clay with Drift	35	55

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	New Steel P. E. 18.97#/ft.	Surface	130

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
Neat Cement	Surface	130	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	

11. MISCELLANEOUS DATA				Well construction completed on 12-8 1972	
Yield test:	1 Hrs. at	14	GPM	Well is terminated 10 inches	<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below
Depth from surface to normal water level		134	ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping		145	ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to System Operational in Feb. '73 laboratory on: 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side. Yield test - Bailing with machine

SIGNATURE <i>Duane Lubbers</i> W.D. 410 Registered Well Driller	COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047
---	--

Please do not write in space below

COLIFORM TEST RESULT 303	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------