MAY 15 1972

# WELL CONSTRUCTOR'S REPORT
FORM 3300–15

**NOTE**
WHITE COPY – DIVISION'S COPY
GREEN COPY – DRILLER'S COPY
YELLOW COPY – OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

**1. COUNTY** Crawford

CHECK ONE: ☐ Town ☒ Village ☐ City — NAME: Bridgeport

**2. LOCATION –** ¼ Section: NW¼ | ¼ Section: NW¼ | Section: 10 | Township: 6-N | Range: 6-W

OR – Grid or street no. | Street name

AND – If available subdivision name, lot & block no.

**3. OWNER AT TIME OF DRILLING** Clyde Willard

ADDRESS: Rte. 2

POST OFFICE: Prairie Du Chien, Wisc. 53821

**4. Distance in feet from well to nearest:** (Record answer in appropriate block)

| BUILDING | SANITARY SEWER C. I. | SANITARY SEWER TILE | FLOOR DRAIN C. I. | FLOOR DRAIN TILE | FOUNDATION DRAIN SEWER CONNECTED | FOUNDATION DRAIN INDEPENDENT | WASTE WATER DRAIN C. I. | WASTE WATER DRAIN TILE |
|---|---|---|---|---|---|---|---|---|
| 11' | 25' | | None | | None | | None | |

| CLEAR WATER DRAIN C. I. | CLEAR WATER DRAIN TILE | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
|---|---|---|---|---|---|---|---|---|---|
| None | | 50' | None | 60' ~~70'~~ | 70' | 70' | None | None | None |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
None

**5. Well is intended to supply water for:**
House

**6. DRILLHOLE**

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|---|---|---|
| 8" | Surface | 132' | 6" | 132 | 197 |

**7. CASING, LINER, CURBING, AND SCREEN**

| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) |
|---|---|---|---|
| 6" | P. E. Steel 18.97 | Surface | 132 |

**8. GROUT OR OTHER SEALING MATERIAL**

| Kind | From (ft.) | To (ft.) |
|---|---|---|
| Neat Cement | Surface | 132 |
| Pumped from bottom up | | |

**9. FORMATIONS**

| Kind | From (ft.) | To (ft.) |
|---|---|---|
| Sandy Clay | Surface | 14 |
| Caving Sand | 14 | 30 |
| Sandy Clay | 30 | 54 |
| Brn. Limestone | 54 | 86 |
| Flint rock, Brn. & White | 86 | 90 |
| Brn. Limestone | 90 | 114 |
| Jordan Sandstone | 114 | 197 |

**10. TYPE OF DRILLING MACHINE USED**

☒ Cable Tool ☐ Direct Rotary ☐ Reverse Rotary
☐ Rotary – air w/drilling mud ☐ Rotary – hammer with drilling mud & air ☐ Jetting with ☐ Air ☐ Water

Well construction completed on 5-5 19 72

**11. MISCELLANEOUS DATA**

Yield test: 5 Hrs. at 12 GPM

Well is terminated 12 inches ☒ above ☐ below final grade

Depth from surface to normal water level 135 ft.

Well disinfected upon completion ☒ Yes ☐ No

Depth to water level when pumping 142 ft.

Well sealed watertight upon completion ☒ Yes ☐ No

Water sample sent to State Lab. of Hygiene, Madison, Wisc. laboratory on: 5-10 19 72

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE: Duane Lubbers
Duane Lubbers — W.D. 410 Registered Well Driller

COMPLETE MAIL ADDRESS
Duane Lubbers
Farmersburg, Iowa 52047

Please do not write in space below

| COLIFORM TEST RESULT | GAS – 24 HRS. | GAS – 48 HRS. | CONFIRMED | REMARKS |
|---|---|---|---|---|
| 304 | | | | |

REV. 3–71