

1. COUNTY Crawford CHECK ONE  Town  Village  City Bridgeport NAME

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Part of S.W. 1/4 of N.E. 1/4 of Section 10 Town 6 Range 6W

3. OWNER AT TIME OF DRILLING  
Henry Prew

4. OWNER'S COMPLETE MAIL ADDRESS  
RR2 Prairie Du Chien, Wisconsin

5. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED/INDEPENDENT	C. I. TILE
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD
C. I. TILE				BARN SILO
	<u>55'</u>		<u>80'</u>	ABANDONED WELL SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:  
Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>86</u>				<u>Top soil</u>	<u>Surface</u>	<u>3</u>
<u>6</u>	<u>86</u>	<u>161</u>				<u>Sandy clay</u>	<u>3</u>	<u>20</u>

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>Standard 19.45</u>	<u>Surface</u>	<u>86</u>	<u>Limestone</u>	<u>20</u>	<u>65</u>
				<u>Hard sandstone</u>	<u>65</u>	<u>80</u>
				<u>Jordon sandstone</u>	<u>80</u>	<u>161</u>

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>cement</u>	<u>Surface</u>	<u>86</u>

11. MISCELLANEOUS DATA

Yield test: 1 Hrs. at 10 GPM

Well construction completed on 6/6 1967

Well is terminated 0 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Depth from surface to normal water level 95 ft.

Depth to water level when pumping 103 ft.

Water sample sent to Madison laboratory on: 6/14 1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Duane Lubbers Registered Well Driller COMPLETE MAIL ADDRESS Box 137 Farmersburg, Iowa

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>3020</u>				