

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION 1/4 Section NW Section 17 Township 6N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Mark Rickards  
 OR - Grid or Street No. Street Name ADDRESS R 2 Box 242  
 AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 100' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Holding Tank Septic Tank 75 Sewage Absorption Unit 80 Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.) Kind From (ft.) To (ft.)

10	Surface	0	84	6	84	200	Clay & sand	Surface	0	70
							limestone	70		200

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)

6	new black steel P.E. 18.97	Surface	0	84		
---	----------------------------	---------	---	----	--	--

A-53  
Valley Steel  
Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

Clay	Surface	0	7
Cement	7	84	

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Reverse Rotary  Jetting with  Air  Water

11. MISCELLANEOUS DATA Yield Test: 4 Hrs. at 5 GPM Well construction completed on 2-25- 1978

Well is terminated 10 inches  above final grade  below final grade

Depth from surface to normal water level 140 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 152 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 3-21- 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copman Registered Well Driller Complete Mail Address Boocabel, Wis. R3 Box 84 53805