

JUN 6 1977

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Kauzeba</u>										
2. LOCATION OR - Grid or Street No. <u>NE 10 7N 4W</u> Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Leonard L. Rose</u>			ADDRESS <u>R1</u>										
AND - If available subdivision name, lot & block No.				POST OFFICE <u>Kauzeba, Wis., 53826</u>											
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer			
		C.I. <u>15'</u> Other		C.I. Other		C.I. Sewer Other Sewer		C.I. Other		C.I. Other		C.I. Other			
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank			
San. Storm		C.I. Other		Sewer Sewage Sump Clearwater Dr.		C.I. Other		Sump		Tank		Sewage Absorption Unit <u>95'</u>			
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard			
				Well Pump Tank		Nonconforming Existing				Silo With Pit		Glass Lined Storage Facility			
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)					
5. Well is intended to supply water for: <u>Trailer home</u>				9. FORMATIONS				Kind		From (ft.)		To (ft.)			
6. DRILLHOLE				DIA. (in.)				From (ft.)		To (ft.)		Kind			
10				Surface				0		46		Clay & sand			
10				6				46		125		sandstone			
10				6				46		125		shalestone			
7. CASING, LINER, CURBING AND SCREEN				Material, Weight, Specification & Method of Assembly				From (ft.)		To (ft.)					
6				new black steel P.E. 18.97 A-53				Surface		0		46			
Valley Steel				Pitless adaptor											
8. GROUT OR OTHER SEALING MATERIAL				Kind		From (ft.)		To (ft.)		10. TYPE OF DRILLING MACHINE USED					
Cement				Surface		0		46		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water					
11. MISCELLANEOUS DATA				Yield Test: <u>5</u> Hrs. at <u>5</u> GPM				Well construction completed on <u>5-19-1977</u>				Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>60</u> Ft.				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Depth of water level when pumping <u>68</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Water sample sent to <u>Madison</u> laboratory on <u>6-2-1977</u>											
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.				Signature <u>Kenneth Coplin</u> Registered Well Driller				Complete Mail Address <u>R3 Box 84</u>				<u>Boscobel, Wis. 53805</u>			