

SEP 9 1974

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Nauzeeka

2. LOCATION - 1/4 Section NE Section 2 Township 7N Range 5W

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Nauzeeka, Wis., 53826

3. OWNER AT TIME OF DRILLING Mr. Al Zink

4. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
<u>15'</u>	<u>30'</u>						

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>60'</u>			<u>75'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>145</u>	<u>6</u>	<u>145</u>	<u>180</u>	<u>sand & Clay</u>	<u>Surface</u>	<u>12</u>
						<u>limestone</u>	<u>12</u>	<u>40</u>
						<u>hard shalestone</u>	<u>40</u>	<u>140</u>
						<u>sandstone</u>	<u>140</u>	<u>180</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>145</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>12</u>
<u>Cement</u>	<u>12</u>	<u>145</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 8-30-1974

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 70 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 84 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-3-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boocabel R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>350</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71