

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

JUL 26 1946

1. County Crawford { Town Wauzeka
Village _____
City _____
2. Location Range 5. W, sec 12. T. 7. N. E. of S. E
3. Owner or Agent Lowell Klein Wauzeka Wis
4. Address Wauzeka Wis
5. From well to nearest: Building 50 ft; sewer _____ ft; drain none ft; septic tank none ft; dry well or filter bed none ft; abandoned well none ft.
6. Well is intended to supply water for: Household use & Stock

7. DRILLHOLE OR EXCAVATION:

Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>0</u>	<u>364</u>

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>Standard</u>	<u>0</u>	<u>31</u>

9. GROUT:

Kind	From (ft.)	To (ft.)

10. FORMATIONS:

Kind	Thick-ness (ft.)	Total Depth (ft.)
<u>Top Soil & gravel</u>	<u>28</u>	<u>28</u>
<u>lime rock</u>	<u>215</u>	<u>243</u>
<u>white sand rock</u>	<u>121</u>	<u>364</u>

11. MISCELLANEOUS DATA:

Yield test: 2 Hrs. at 5 GPM.
Depth from surface to water: 339 ft.
Water-level when pumping: 339 ft.

Water sample sent to laboratory at Madison on 25 July 1946

Signature E S Waters
Registered Well Driller

Construction of the well was completed on June 27 1946

The well is terminated 18 inches (above) (below) the permanent grade.

Was the well disinfected upon completion? Yes No _____

Was the well sealed watertight upon completion? Yes No _____

500 Walnut St Bos cobel Wis
Complete Mail Address