

SEP 1 1981
 JUL 28 1981
 wed

1. COUNTY Crawford CHECK (✓) ONE:
 Town Village City Prairie du Chien

2. LOCATION 1/4 Section or Gov't. Lot NE Section 10 Township 7N Range 6W
 OR - Grid or Street No. Street or Road Name ADDRESS Rt. 1
 AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien WI ZIP CODE

3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Louis Horkheimer

4. Distance in feet from well to nearest: (Record answer in appropriate block) 30'
 Building Sanitary Bldg. Drain Sanitary Bldg. Sewer Floor Drain Connected To: Storm Bldg. Drain Storm Bldg. Sewer
 C.I. Other C.I. Other C.I. Sewer Other Sewer C.I. Other C.I. Other
 Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Manure Hopper or Retention or Pneumatic Tank
 San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other Clearwater Sump 50' Seepage Pit Seepage Bed Seepage Trench
 Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Or Pit Earthen Manure Basin
 Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	430	6	430	480

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	P.E. 18.97 lbs/ft	Surface	0	430
	A53 Livingston			
	Pipe & Tube			
	Putless adapter			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
loose limestone	Surface	40
limestone	40	70
shale	70	90
limestone	90	105
shale	105	120
limestone	120	145
shale	145	165
sandstone	165	330
limestone	330	360
sandstone w/clay	360	400
limestone	400	480

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	430

Well construction completed on 10-24 1980

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 9 GPM Well is terminated 15 inches above below final grade

Depth from surface to normal water level 380 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 387 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 7-20 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Corpiam Registered Well Driller Business Name and Complete Mailing Address Kenneth Corpiam & Sons, Inc
Rt. 2 Box 4 Boscobel, WI 53805