

NOV 14 1979

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

NOTE:

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Wauszeka

2. LOCATION 1/4 Section NW Section 15 Township 7N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Paul Peloch

OR - Grid or Street No. Street Name ADDRESS R R 1

AND - If available subdivision name, lot & block No. POST OFFICE Wauszeka, WI, 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewer Sewage Sump C.I. Other Clearwater Sump Clearwater Dr. Septic Tank Holding Tank Sewage Absorption Unit 60' Seepage Pit Seepage Bed Seepage Trench 55'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	123	6	123	360	Clay & loose stone	Surface	0	30
						soft sandstone		30	60
						broken limestone		60	100
						limestone		100	297
						sandstone		297	360

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)

6 new black steel P.E. 18.97 A-53 From (ft.) 0 To (ft.) 123

Keystone Pipe
 Pelless adapter

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

Clay Surface 0 8
 Cement 8 123

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with
 Rotary-air w/drilling mud Rotary-hammer & air Air
 Rotary-w/drilling mud Reverse Rotary Water

11. MISCELLANEOUS DATA Yield Test: 3 Hrs. at 5 GPM Well construction completed on 10-12-1979
 above final grade
 below final grade

Depth from surface to normal water level 268 Ft. Well disinfected upon completion Yes No
 Depth of water level when pumping 279 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-5-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Henneth Copian Registered Well Driller Complete Mail Address R2 Box 4 Boscebel, WI, 53805