

WELL CONSTRUCTOR'S REPORT

WISCONSIN STATE BOARD OF HEALTH

Well 6

1. COUNTY Crawford CHECK ONE  Town  Village  City Wazeka NAME

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Range 5W Township 7N. Section 22 RECEIVED

3. OWNER AT TIME OF DRILLING Raymond Gaidowski AUG 26 1966

4. OWNER'S COMPLETE MAIL ADDRESS Wazeka, Wisconsin

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	SANITARY ENGINEER'S C. I.	WATER DRAIN TILE		
20	40							
CLEAR WATER DRAIN C. I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	75		150				plugged 15	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	198				Top soil	Surface	3
6	198	307				Clay	3	20
8. CASING, LINER, CURBING, AND SCREEN								
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)				
6	6" 19.45		Surface	198		20 Flint	20	35
						1/2 Brown limestone	35	118
						Gray limestone	118	160
						Brown limestone	160	185
						Caving brown limestone	185	190
						Brown limestone	190	200
9. GROUT OR OTHER SEALING MATERIAL								
Kind			From (ft.)	To (ft.)				
cement			Surface	198		Hard sandstone	200	231
						Sand stone	231	307
						Well construction completed on	8/16	1966

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 251 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 251 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 8/16 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Duane Lubbers Registered Well Driller COMPLETE MAIL ADDRESS Farmersburg, Iowa

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
368				