

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

RECEIVED
AUG 24 1953
ENVIRONMENTAL
SANITATION

1. County Crawford { Town Waauzeka
Village
City
2. Location Sec 28, T7N, 5W On Highway sixty
3. Owner or Agent Hal Russel
4. Address Bridgeport - Wis
5. From well to nearest: Building 8 ft; sewer ft; drain ft; septic tank ft;
dry well or filter bed ft; abandoned well ft.
6. Well is intended to supply water for: Home

7. DRILLHOLE OR EXCAVATION:

Dia. (in.)	From (ft.)	To (ft.)
6	0	56
		56

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
6	standard cemented in	0	21

9. GROUT:

Kind	From (ft.)	To (ft.)

10. FORMATIONS:

Kind	Thick-ness (ft.)	Total Depth (ft.)
Top Soil	5	5
Lime Rock	19	24
Shale	32	56

11. MISCELLANEOUS DATA:

Yield test: 4 Hrs. at 10 GPM.

Depth from surface to water: 25 ft.

Water-level when pumping: 25 ft.

Water sample sent to laboratory at
 Madison on Aug 17 19 53

Construction of the well was completed on July 10
 19 53

The well is terminated 12 inches
(above) (below) the permanent grade.

Was the well disinfected upon completion?
Yes No

Was the well sealed watertight upon completion?
Yes No

Signature Joseph Dull
Registered Well Driller

Waauzeka Wis.
Complete Mail Address
 Joe