

NOV 14 1979

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

NOTE:

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Wauszeka

2. LOCATION NW Section 30 Township 7N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Richard Toberman

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other					Seepage Pit	6.5'
														Seepage Bed	
														Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							
		Pump								
		Tank								

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	69	6	69	420

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	20
broken limestone	20	52
hard limestone	52	213
sandstone	213	300
hard shalestone	300	327
limestone	327	369
hard shalestone	369	420

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53 Keystone Pipe Piless adapter	Surface	69

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	69

Well construction completed on 10-24-1979

Well is terminated 10 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 7 GPM

Depth from surface to normal water level 340 Ft.

Depth of water level when pumping 352 Ft. Stabilized  Yes  No

Water sample sent to Madison laboratory on 11-5-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coyman Registered Well Driller

Complete Mail Address Boccobell, Wis. R2 Box 4 53805

346