

MAY 20 1985

1. COUNTY CRAWFORD CHECK (✓) ONE: Town Village City Name PRAIRIE DU CHIEN

2. LOCATION SE 1/4, NW 1/4 Section 14 Township T7M Range R6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS 417 N. ILL. ST.

AND - If available subdivision name, lot & block No. POST OFFICE PRAIRIE DU CHIEN ZIP CODE WI. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 50' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed 175' Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Private Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	345			
6"	345	425			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END 18.97 United Steel CA Conduen	0 Surface	345

9. FORMATIONS

Kind	From (ft.)	To (ft.)
CLAY	0 Surface	38'
LIME ROCK & CREVICE	38'	57'
BLUE CLAY	57'	63'
LIME ROCK	63'	110'
SAND ROCK	110'	215'
LIME ROCK + CREV.	215'	333'
LIME ROCK	333'	425'

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	7 Surface	345
Sbury Tank	0	7

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 5-7 1985

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 10 GPM Well is terminated 10 inches above below final grade

Depth from surface to normal water level 315 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 345 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON laboratory on 5-15 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cousin Registered Well Driller Business Name and Complete Mailing Address CORPIAN WELL DRILLING
BOSCOBEL WI. 53805