

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**  
**See Instructions on Reverse Side**

1. County Crawford Town  Bridgport  
 Village   
 City  Check one and only one

2. Location R. 6 W. T. 7 N.  
 Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Irish Ridge Cheese Factory  
 Name of individual, partnership or firm

4. Mail Address Bridgport RR #  
 Complete address required

5. From well to nearest: Building 6 ft; sewer \_\_\_\_\_ ft; drain none ft; septic tank \_\_\_\_\_ ft;  
 dry well or filter bed \_\_\_\_\_ ft; abandoned well \_\_\_\_\_ ft.

6. Well is intended to supply water for: Factory & Home

**7. DRILLHOLE:**

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	42 1/2			
6	42 1/2	485			

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	St. Wgt. Blk. Steel	0	42 1/2

**9. GROUT:**

Kind	From (ft.)	To (ft.)
Neat Cement	38	42 1/2
Cement	6	38

**11. MISCELLANEOUS DATA:**

Yield test: 4 Hrs. at 10 GPM.  
 Depth from surface to water-level: 450 ft.  
 Water-level when pumping: 450 ft.  
 Water sample was sent to the state laboratory at:  
Not Submitted 19\_\_\_\_  
 City

**10. FORMATIONS:**

Kind	From (ft.)	To (ft.)
Old Well	0	135
Lower Trenton	135	182
St. Peter sand	182	239
Prairie Du Chien	239	485
Water 450		

Construction of the well was completed on:  
April 17 1954

The well is terminated 14 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
 Yes  No \_\_\_\_\_

Was the well sealed watertight upon completion?  
 Yes  No \_\_\_\_\_

Signature Tony Beets Registered Well Driller  
 Complete Mail Address Box 503 Cuba City, Wis.

Please do not write in space below

Rec'd \_\_\_\_\_ No. \_\_\_\_\_  
 Ans'd \_\_\_\_\_  
 Interpretation \_\_\_\_\_

10 ml 10 ml 10 ml 10 ml 10 ml  
 Gas—24 hrs. \_\_\_\_\_  
 48 hrs. \_\_\_\_\_  
 Confirm \_\_\_\_\_  
 B. Coli \_\_\_\_\_  
 Examiner \_\_\_\_\_

