

WELL CONSTRUCTOR'S REPORT  
 FOF 3300-15

MAY 09 1974

JUL 1 - 1974

STATE OF WISCONSIN  
 DEPARTMENT OF NATURAL RESOURCES  
 Box 450  
 Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
 GREEN COPY - DRILLER'S COPY  
 YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Bridgeport

2. LOCATION - 1/4 Section S.E. Section 1 Township 7N Range 6W 3. OWNER AT TIME OF DRILLING Paul Flansburgh

OR - Grid or street no. Street name ADDRESS R2

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest:  
 (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	C.I.	C.I.	SEWER CONNECTED	INDEPENDENT
<u>50'</u>	<u>60'</u>			

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	<u>54'</u>			<u>70'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>10</u>	<u>6</u>	<u>10</u>	<u>95</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>	
						<u>loose sand</u>	<u>10</u>	<u>50</u>	
						<u>sandstone</u>	<u>50</u>	<u>80</u>	
						<u>hard shale stone</u>	<u>80</u>	<u>95</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)		<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
<u>Clay</u>	<u>Surface</u>	<u>10</u>		<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with	<input type="checkbox"/> Air <input type="checkbox"/> Water
<u>loose sand</u>	<u>10</u>	<u>50</u>		Well construction completed on <u>4-15-1974</u>			

11. MISCELLANEOUS DATA			
Yield test:	<u>3</u> Hrs. at	<u>8</u> GPM	Well is terminated <u>24</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	<u>40</u> ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>41</u> ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 5-6-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis., 53805

COLIFORM TEST RESULT <u>387</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				