

SEP 20 1979

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

NOTE:

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Bridgeport</u>	
2. LOCATION		1/4 Section <u>SW</u>	Section <u>3</u>	Township <u>7N</u>	Range <u>6W</u>
OR - Grid or Street No. Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		ADDRESS <u>Steve E. Welter</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE		<u>RFD</u> <u>Prairie du Chien, WI 53821</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
Street Sewer San. Storm		Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump Septic Tank Holding Tank
Sewage Absorption Unit <u>85'</u>		Sewage Pit Seepage Bed Seepage Trench			
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for <u>Country home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>100</u>	<u>6</u>	<u>100</u>	<u>260</u>
					<u>Clay</u>
					<u>limestone</u>
					<u>sandstone</u>
					<u>shalestone</u>
7. CASING, LINER, CURBING AND SCREEN			10. TYPE OF DRILLING MACHINE USED		
Material, Weight, Specification & Method of Assembly			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary		
Dia. (in.)	From (ft.)	To (ft.)	Well construction completed on <u>8-25-</u> 19 <u>79</u>		
<u>6</u>	<u>Surface</u>	<u>100</u>	Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
<u>new black steel P.E. 18.97 A-53 Keystone Pipe Pitless Adapter</u>			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
8. GROUT OR OTHER SEALING MATERIAL			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Kind			Water sample sent to <u>Madison</u> laboratory on <u>9-18-</u> 19 <u>79</u>		
From (ft.) To (ft.)			Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		
<u>Clay</u> <u>8</u> <u>100</u>			Signature <u>Kenneth Coplan</u> Registered Well Driller		
<u>Cement</u> <u>8</u> <u>100</u>			Complete Mail Address <u>Boscobel WI</u> <u>R2 Box 4 53805</u>		
11. MISCELLANEOUS DATA			392		
Yield Test: <u>3</u> Hrs. at <u>15</u> GPM					
Depth from surface to normal water level <u>80</u> Ft.					
Depth of water level when pumping <u>10.5</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					