

AUG 7 1973

34146

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Bridgeport

2. LOCATION - 1/4 Section SE Section 3 Township 7N Range 6W 3. OWNER AT TIME OF DRILLING Curtis L. Swenson

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
10'	C.I. 18'	TILE 20'	SEWER CONNECTED	INDEPENDENT
CLEAR WATER DRAIN		SEPTIC TANK	PRIVY	SEEPAGE PIT
C.I. TILE		65'		
			ABSORPTION FIELD	BARN
			80'	SILO
				ABANDONED WELL
				SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	45	6	45	180	Clay	Surface	35
						limestone	35	110
						sandstone	110	180

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	45

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	35
Cement	35	45

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 7-11-1973

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 8 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 108 ft.

Well disinfected upon completion Yes No

Depth to water level when pumping 120 ft.

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 8-1-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boocabel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>393</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71