

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JUL 18 1973

NOTE 27734

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Bridgeport

2. LOCATION - 1/4 Section NE Section 3 Township 7N Range 6W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Robert Vuilleminot
ADDRESS R2

AND - If available subdivision name, lot & block no. POST OFFICE 53821
Prairie du Chien, Wis.

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>10'</u>	<u>20'</u>		<u>30'</u>				

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>65'</u>			<u>80'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>44</u>	<u>6</u>	<u>44</u>	<u>180</u>	<u>Clay</u>	<u>Surface</u>	<u>30</u>
						<u>limestone</u>	<u>30</u>	<u>110</u>
						<u>sandstone</u>	<u>110</u>	<u>180</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain ends 19.18</u>	<u>Surface</u>	<u>44</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>30</u>
<u>Cement</u>	<u>30</u>	<u>44</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 7 GPM

Well construction completed on 6-26-1973

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 100 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 108 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-9-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copians Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>394</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------