

Well No. 2

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

NOTE:

APR 16 1985 CR-198

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name See permit
 2. LOCATION East 1/2, 23 Section 23 Township 7N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street or Road Name ADDRESS RR. 1 (Bill Herseid, Jr) #2
 AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wi. ZIP CODE 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

| Building | | Sanitary Bldg. Drain | | Sanitary Bldg. Sewer | | Floor Drain Connected To: | | Storm Bldg. Drain | | Storm Bldg. Sewer | |
|----------|--|----------------------|-------|----------------------|-------|---------------------------|-------------|-------------------|-------|-------------------|-------|
| | | C.I. | Other | C.I. | Other | C.I. | Other Sewer | C.I. | Other | C.I. | Other |

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewage Sump: C.I. Other Clearwater Sump: Clearwater Dr. Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom: Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin: Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe) sewer main 57'

5. Well is intended to supply water for: trailer park

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|---------------|----------------|-----------|------------|------------|----------|
| <u>12 1/4</u> | <u>Surface</u> | <u>63</u> | | | |
| <u>7 7/8</u> | <u>63</u> | <u>77</u> | | | |

9. FORMATIONS

| Kind | From (ft.) | To (ft.) |
|--------------------------|----------------|-----------|
| <u>sand & gravel</u> | <u>Surface</u> | <u>10</u> |
| <u>gravel</u> | <u>10</u> | <u>77</u> |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification | From (ft.) | To (ft.) |
|------------|---------------------------------|----------------|-----------|
| <u>8</u> | <u>Std. Blk pipe</u> | <u>Surface</u> | <u>63</u> |
| | <u>280 wall</u> | | |
| | <u>weld jts.</u> | | |
| | <u>A-53</u> | | |
| | <u>0.322 wall - see</u> | | |
| | <u>6/19/85 note from Sam V.</u> | | |

15 ft. #20 slot stainless steel screen installed - top of packer at 61 ft.

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|----------------------|----------------|-----------|
| <u>cement (Neat)</u> | <u>Surface</u> | <u>63</u> |

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on Oct. 10 1984

11. MISCELLANEOUS DATA

Yield Test: 6 Hrs. at 125 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 18 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 55 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Sent in by owner for laboratory on 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Sam Vander Grint spec. cap. = 2.4 gpm/ft Registered Well Driller Business Name and Complete Mailing Address SAM'S ROTARY DRILLERS
CC3 WCD OTM FILE
565
WELL LOG BOOK
ROUTE 2
RANDOLPH, WISCONSIN 53956