

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

MAY 11 1978

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Prairie du Chien

2. LOCATION  $\frac{1}{4}$  Section NW Section 6 Township 7N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 OR - Grid or Street No. Street Name ADDRESS Bernard Pedretti  
RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 40' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 200'  
 San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other C.I. Other

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit 100' 200'

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	125	6	125	140

9. FORMATIONS

Kind	From (ft.)	To (ft.)
loose sand	Surface	30
sand & Clay	30	110
sandstone	110	140

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97	Surface	125
	A-53		
	Valley Steel		
	Pitless adaptor		

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	125

Well construction completed on 4 - 26 - 1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 80 Ft.

Depth of water level when pumping 102 Ft. Stabilized  Yes  No

Well is terminated 14 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 5 - 8 - 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805