

WELL CONSTRUCTORS REPORT

STATE OF WISCONSIN  
DEPARTMENT OF RESOURCE DEVELOPMENT

SEP 28 1970

APR 24 1970 Wel 6

1. COUNTY CRAWFORD CHECK ONE  Town  Village  City NAME PRAIRIE DU CHIEN, WIS.

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
SOUTH 400' GOVERNMENT LOT 3 - 87 - T12N 7 - R6W

3. OWNER AT TIME OF DRILLING RAY CHILDS

4. OWNER'S COMPLETE MAIL ADDRESS R.F.D. NO. 1 PRAIRIE DU CHIEN, WIS.

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
10'				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	55 ft.	none	100'		none	none	none	none

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
NONE

6. Well is intended to supply water for: HOME ONLY

7. DRILLHOLE			10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
4"	Surface	131		Surface	
				dirt and drift.	35
				SAND AND GRAVEL.	35 - 65
				JORDAN SAND SOFT.	65 - 121
				JORDAN SAND HARD	121 - 131

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
4 1/2"	YOUNGSTOWN STEEL	Surface	121'
	<i>New. - 10.89 per ft.</i>		
	F 21--T 2--1200		
	with drive shoe		
	PLAIN END CASING		

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
NONE	Surface	

11. MISCELLANEOUS DATA

Yield test: <u>4</u> Hrs. at <u>12</u> GPM	Well construction completed on <u>NOV. 25</u> 19 <u>69</u>
Depth from surface to normal water level <u>51</u> ft.	Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth to water level when pumping <u>60</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to MADISON, WIS. laboratory on: MARCH 13 1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Lewis Harris COMPLETE MAIL ADDRESS 327 N. MAIN ST. PRAIRIE, DU CHIEN, WIS.  
Registered Well Driller

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
415				