

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Prairie Du Chien

2. LOCATION SW of NW Section 28 Township 7N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Don Knapp

OR - Grid or Street No. Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE, Prairie Du Chien WI ZIP CODE 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 100'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Seepage Pit	Seepage Bed	Seepage Trench	Manure Hopper or Retention or Pneumatic Tank			

500'

Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard		Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit		Earthen Silage Storage Trench Or Pit		Earthen Manure Basin	
Well	Pump	Tank	Nonconforming Existing	Nonconforming Existing	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin												

Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)	
Concrete Floor Only	Concrete Floor and Partial Concrete Walls	Other (Describe)											

5. Well is intended to supply water for: Country Homes

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0 Surface	84	6	84	500

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97	0 Surface	84
	A-53		
	Valley steel		
	Pitless adaptor		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	Surface	15
lime rock	15	165
sand stone	165	215
Line rock	215	500

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	0 Surface	8
cement	8	84

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 12-30 1982

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 15 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 440 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 450 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison WI laboratory on 1-13 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Knackbaum Registered Well Driller Business Name and Complete Mailing Address Don's Well Drilling Bozobel WI