

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15  
Rev. 10-75

SEP 8 1976

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Prairie Du Chien Name

2. LOCATION SW Section 9 Township 7N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
ADDRESS Dr. M. M. Shihata  
RFD  
POST OFFICE Prairie Du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. 30 Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump C.I. Other Clearwater Sump Clearwater Dr. Sewage Absorption Unit 7.5' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	121	6	121	560	Clay	Surface	45
						limestone	45	80
						soft sandstone	80	100
						limestone	100	300
						hard shale	300	480
						hard sandstone	480	560

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	121

Valley Steel  
Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	121

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 8-12- 19 76

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 8 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 4.50 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 4.80 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 8-30- 19 76

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cyprian Registered Well Driller Complete Mail Address Boscobel  
R3 Box 84 Wis. 53805