

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION NW Section 9 Township 7 N Range 6 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street Name ADDRESS R2

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, WI 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 12' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump C.I. Other Clearwater Sump Clearwater Dr. Clearwater Sump Clearwater Dr. Sewage Absorption Unit 80' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

9. FORMATIONS

6. DRILLHOLE						Kind	From (ft.)	To (ft.)
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)			
<u>10</u>	<u>Surface</u>	<u>63</u>	<u>6</u>	<u>63</u>	<u>170</u>	<u>Clay &amp; stone</u>	<u>Surface</u>	<u>20</u>
						<u>broken limestone</u>	<u>20</u>	<u>50</u>
						<u>hard limestone</u>	<u>50</u>	<u>100</u>

7. CASING, LINER, CURBING AND SCREEN  
Material, Weight, Specification & Method of Assembly  
Dia. (in.) From (ft.) To (ft.)  
6 new black steel 0 63  
R.E. 18.97 Surface  
A-53  
Valley Steel  
Pitless adaptor

<u>hard sandstone</u>	<u>100</u>	<u>120</u>
<u>limestone</u>	<u>120</u>	<u>170</u>

8. GROUT OR OTHER SEALING MATERIAL  
Kind From (ft.) To (ft.)  
Clay Surface 7  
Cement 7 63

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water  
 Rotary-air w/drilling mud  Rotary-hammer & air  
 Rotary-w/drilling mud  Reverse Rotary

11. MISCELLANEOUS DATA  
Yield Test: 2 Hrs. at 5 GPM  
Depth from surface to normal water level 90 Ft.  
Depth of water level when pumping 102 Ft. Stabilized  Yes  No

Well construction completed on 5-2-1979  
Well is terminated 10 inches  above final grade  below  
Well disinfected upon completion  Yes  No  
Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-4-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, WI  
R3 Box 84 53805