

SEP 8 1976

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Bridgeport

2. LOCATION 1/4 Section NW Section 9 Township 7N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Charles Kramer

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie Du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20' Sanitary Bldg. Drain C.I. 30' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Absorption Unit 95' Seepage Pit Seepage Bed Seepage Trench

Septic Tank 70' Holding Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>88</u>	<u>6</u>	<u>88</u>	<u>120</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>40</u>
<u>soft sandstone</u>	<u>40</u>	<u>75</u>
<u>hard sandstone</u>	<u>75</u>	<u>120</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>88</u>
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>88</u>

Well construction completed on 8-17-1976

Well is terminated 12 inches above final grade below

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 6 GPM

Depth from surface to normal water level 60 Ft.

Depth of water level when pumping 68 Ft. Stabilized Yes No

Water sample sent to Madison laboratory on 8-30-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boacohels, Wis. R3 Box 84 53805