

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JAN 14 1976

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Bridgeport

2. LOCATION - 1/4 Section SW Section 10 Township 7N Range 6W
OR - Grid or street no. Street name ADDRESS Jack Williams
R7D

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
10'	C.I. 120'	TILE 100'	SEWER CONNECTED INDEPENDENT	C.I. TILE

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C.I. TILE	125'			130'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	191	6	191	200	soft sandstone		Surface	80
						hard sandstone		80	200

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain ends 18.97	Surface	191
	A-53		
	Valley Steel		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
loose sand	Surface	3
Cement	3	191

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer Jetting with Air Water

Well construction completed on 12-8-1975

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 160 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 168 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 1-12-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Herbert Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boesobel
R3 Box 84 Wis., 53805

COLIFORM TEST RESULT 426 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71