

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

JUL 16 1973

27731

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Bridgeport

2. LOCATION - 1/4 Section SW Section 10 Township 7N Range 6W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Mr. Frank Weeks

ADDRESS R1 53821

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis.

4. Distance in feet from well to nearest:

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE
<u>25'</u>	<u>54'</u>						

(Record answer in appropriate block)

CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	<u>70'</u>			<u>85'</u>	<u>200'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>54</u>	<u>6</u>	<u>54</u>	<u>180</u>	<u>Clay</u>	<u>Surface</u>	<u>20</u>
						<u>Clay &amp; stone</u>	<u>20</u>	<u>48</u>
						<u>limestone</u>	<u>48</u>	<u>125</u>
						<u>sandstone</u>	<u>125</u>	<u>180</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>54</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>20</u>
<u>Cement</u>	<u>20</u>	<u>54</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 6-12-1973

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 14 inches  above  below final grade

Depth from surface to normal water level 125 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 136 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-9-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>427</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71