

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <i>Prairie du Chien</i>		
2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) <i>NE 1/4 of SW 1/4 of Sec 11 T7N R6W</i>						
3. OWNER AT TIME OF DRILLING <i>Rolf Loewenhagen</i>						
4. OWNER'S COMPLETE MAIL ADDRESS <i>RD 70 Prairie du Chien, Wis.</i>						
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
		C. I.	TILE	C. I.	TILE	SEWER CONNECTED INDEPENDENT
		<i>8'</i>				
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO
C. I.	TILE					
		<i>58'</i>				
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

6. Well is intended to supply water for: *Private home*

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<i>10</i>	<i>Surface</i>	<i>61</i>	<i>6</i>	<i>61</i>	<i>185</i>	<i>Clay</i>	<i>Surface</i>	<i>25</i>
						<i>limestone</i>	<i>25</i>	<i>103</i>
						<i>sandstone</i>	<i>103</i>	<i>185</i>

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<i>6</i>	<i>black - new plain end 19.18</i>	<i>Surface</i>	<i>61</i>

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<i>Clay</i>	<i>Surface</i>	<i>25</i>
<i>Cement</i>	<i>25</i>	<i>61</i>

11. MISCELLANEOUS DATA		Well construction completed on <i>3-29-</i> 19 <i>68</i>	
Yield test: <i>3</i> Hrs. at <i>20</i> GPM	Well is terminated <i>12</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Depth from surface to normal water level <i>160</i> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth to water level when pumping <i>163</i> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <i>Madison, Wis.</i>	laboratory on: <i>April 3</i> 19 <i>68</i>		

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE <i>Berneth Coyman</i>	COMPLETE MAIL ADDRESS <i>R3 Box 84 Boscobel, Wis. 53805</i>
Registered Well Driller	
Please do not write in space below	

COLIFORM TEST RESULT <i>431</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------