

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie du Chien

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SW Part of Sec 15 T7N R6W

3. OWNER AT TIME OF DRILLING Erden Berger Erdenberger Bros.

4. OWNER'S COMPLETE MAIL ADDRESS R1 Prairie du Chien, Wis. 53821

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
8'	C. I.	C. I.	SEWER CONNECTED	C. I.
	TILE	TILE	INDEPENDENT	TILE

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE				200'	300'	50'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	45	6	45	520	Clay	Surface	15	
						blue limestone	15	90	
						sandstone	90	160	
						limestone	160	490	
						sandstone	490	520	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain ends 19.18	Surface	45

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	45

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 10 GPM Well is terminated 24 inches above below final grade

Depth from surface to normal water level 470 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 473 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: 8-21- 1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
441				