

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie du Chien

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Sec 18 Town TN Range 7W

3. OWNER AT TIME OF DRILLING Elliot Franklin

4. OWNER'S COMPLETE MAIL ADDRESS R7D Prairie du Chien, Wis.

5. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
(Record answer in appropriate block)	C. I.	TILE	C. I.	TILE
8'			15'	15'

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
15'		65'	0	70'	0	0	0	0

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) None

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	70	6	70	95	Clay	Surface	20
						limestone	20	30
						soft sandstone	30	60
						hard sandstone	60	95

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	Standard 19.15 wt.	Surface	70

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	70

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 25 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 50 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 53 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 1-10 - 1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copman Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 36 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
444				