

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

SEP 19 1974

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City Prairie du Chien NAME Prairie du Chien

2. LOCATION - 1/4 Section SE Section 20 Township 7N Range 7W 3. OWNER AT TIME OF DRILLING William Adamany
OR - Grid or street no. Street name 6 ADDRESS R 701 Cliffwood Rd
AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis., 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER C. I.	TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE	
<u>10'</u>	<u>23'</u>		<u>23'</u>						
CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>80'</u>			<u>94'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>70</u>	<u>6</u>	<u>70</u>	<u>120</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay & loose stone</u>	<u>Surface</u>	<u>70</u>
<u>loose sand</u>	<u>70</u>	<u>80</u>
<u>sandstone</u>	<u>80</u>	<u>120</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>91</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>70</u>
<u>loose sand</u>	<u>70</u>	<u>80</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 8-23-1974

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-16-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Box 84
Madison, Wis., 53805

COLIFORM TEST RESULT 452 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS