

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Prairie du Chien</u>	
2. LOCATION 1/4 Section <u>NW</u> Section <u>20</u> Township <u>7N</u> Range <u>6W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Eldon Hirsch</u>			
OR - Grid or Street No. Street Name		ADDRESS <u>R1 Prairie du Chien,</u>			
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Cliffwood Drive WI, 53821</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>		Sanitary Bldg. Drain C.I. Other	
				Sanitary Bldg. Sewer C.I. Other	
				Floor Drain Connected To: C.I. Sewer Other Sewer	
				Storm Bldg. Drain C.I. Other	
				Storm Bldg. Sewer C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm C.I. Other		Sewer		Sewage Sump C.I. Other	
		Clearwater Dr.		Clearwater Sump	
				Clearwater Sump	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Well Pump Tank	
				Subsurface Pumproom Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Country homes</u>				9. FORMATIONS	
6. DRILLHOLE				Kind	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				From (ft.) To (ft.)	
<u>10</u> <u>Surface</u> <u>120</u> <u>6</u> <u>120</u> <u>140</u>				<u>Clay &amp; loose stone</u> <u>Surface</u> <u>100</u>	
				<u>sandstone</u> <u>100</u> <u>140</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.)		From (ft.)		To (ft.)	
<u>6</u>		<u>Surface</u>		<u>120</u>	
<u>new black steel P.E. 18.97 A-53</u>					
<u>Keystone Pipe</u>					
<u>Pitless adapter</u>					
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)		To (ft.)	
<u>Clay</u>		<u>Surface</u>		<u>7</u>	
<u>Cement</u>		<u>7</u>		<u>120</u>	
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
Well construction completed on <u>9-20-</u> 19 <u>79</u>					
11. MISCELLANEOUS DATA					
Yield Test: <u>4</u> Hrs. at <u>5</u> GPM		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>80</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>86</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <u>Madison</u> laboratory on <u>10-9-</u> 19 <u>79</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u> Registered Well Driller			Complete Mail Address <u>Boscobel WI,</u> <u>R2 Box 4</u> <u>53805</u>		