

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City Prairie du Chien	
2. LOCATION 1/2 Section SE Section 30 Township 7N Range 6W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Thomas Cornford	
OR - Grid or Street No. Street Name		ADDRESS RR1 Box 431A	
AND - If available subdivision name, lot & block No.		POST OFFICE Prairie du Chien, WI 53821	
4. Distance in feet from well to nearest: (Record answer in appropriate block)	Building 12'	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other
Street Sewer San. Storm	Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	Sewage Sump C.I. Other
Privy	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter Animal Barn Pen Animal Yard Silo With Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank
		Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for: Country home		9. FORMATIONS	
6. DRILLHOLE		Kind	
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)
10	0 Surface	72	6
			72
			100
			Clay & stone
			hard sandstone
			Surface 0
			60
			60
			100
7. CASING, LINER, CURBING AND SCREEN		10. TYPE OF DRILLING MACHINE USED	
Material, Weight, Specification & Method of Assembly		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water	
Dia. (in.)	From (ft.)	To (ft.)	
6	0 Surface	72	
new black steel P.E. 18.97 A-53			
Kent Steel			
Pitless adapter			
8. GROUT OR OTHER SEALING MATERIAL		Well construction completed on 5-14-1980	
Kind	From (ft.)	To (ft.)	
Clay	0 Surface	8	
Cement	8	72	
11. MISCELLANEOUS DATA		Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Yield Test: 2 Hrs. at 6 GPM	Depth from surface to normal water level 60 Ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping 73 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Water sample sent to Madison laboratory on 5-21-1980	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		Signature Kenneth Cornford Registered Well Driller	
Complete Mail Address Roscobel, WI		R2 Box 4	
		53805	