

JUN 13 1977

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Prairie du Chien

2. LOCATION % Section NW Section 23 Township 7N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Robert Clark

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>20'</u>	C.I. <u>35'</u> Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other
Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other		Holding Tank
					Sewage Absorption Unit <u>85'</u>
					Seepage Pit
					Seepage Bed
					Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>140</u>	<u>6</u>	<u>140</u>	<u>200</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>
						<u>limestone</u>	<u>15</u>	<u>25</u>
						<u>broken limestone and clay</u>	<u>25</u>	<u>130</u>
						<u>hard limestone</u>	<u>130</u>	<u>200</u>

7. CASING, LINER, CURBING AND SCREEN
 Material, Weight, Specification
 Dia. (in.) & Method of Assembly From (ft.) To (ft.)

6 new black steel P.E. 18.97 Surface 0 140

A-53

Valley Steel

Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>140</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 6-3- 1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 135 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 156 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-7- 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth C. Poyian Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805