

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

SEP 14 1973

SEP 19 1973

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Prarie du Chien

2. LOCATION - 1/4 Section SE Section 29 Township T7N Range R6W 3. OWNER AT TIME OF DRILLING Tom White

OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Prarie du Chien

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
	<u>30</u>						

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>75</u>							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: farm

6. DRILL HOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>380</u>			
<u>6</u>	<u>380</u>	<u>652</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>23</u>
<u>Galena Lime</u>	<u>23</u>	<u>51</u>
<u>Upper Platteville</u>	<u>51</u>	<u>85</u>
<u>Trenton Lime</u>	<u>85</u>	<u>140</u>
<u>St Peter</u>	<u>140</u>	<u>225</u>
<u>May Lime</u>	<u>225</u>	<u>490</u>
<u>Trempealeau sand</u>	<u>490</u>	<u>595</u>
<u>Trempealeau lime</u>	<u>595</u>	<u>652</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>New Steel T &amp; C 19.18</u>	<u>Surface</u>	<u>380</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>380</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 11-14 1972

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 20 GPM

Well is terminated 5 ftches  above  below final grade

Depth from surface to normal water level 510 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 540 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: Sept 14 1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph Faherty Registered Well Driller COMPLETE MAIL ADDRESS FAHERTY DRILLING CO., INC.  
1120 Broadway  
PLATTEVILLE, WISCONSIN 53818

COLIFORM TEST RESULT 471 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71