

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

Name Glen Beniker
Bridgeport

1. COUNTY Crawford CHECK (✓) ONE:
 Town Village City

2. LOCATION 1/2 Section SW Section 32 Township 7N Range 6W
 OR - Grid or Street No. Street Name

3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Bridgeport & Prairie du Chien
 ADDRESS Fire Dept.

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) 10'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump				Seepage Pit	<u>125'</u>
											Seepage Bed	
											Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							
		Pump								
		Tank								

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Fire Dept. building

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>0</u> Surface	<u>165</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>0</u> Surface	<u>115</u>
<u>sandstone</u>	<u>115</u>	<u>125</u>
<u>limestone</u>	<u>125</u>	<u>145</u>
<u>shalestone</u>	<u>145</u>	<u>165</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u> <u>P.E. 18.97</u> <u>A-53</u>	<u>0</u> Surface	<u>132</u>
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
	<u>Surface</u>	

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on Oct. 22 - 1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 50 GPM

Depth from surface to normal water level 60 Ft.

Depth of water level when pumping 120 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Nov. 15 - 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller

Complete Mail Address Baseobel, Wis.
R3 Box 84
53805