

1. COUNTY Crawford CHECK ONE Town Village City NAME Bridgeport

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SE 1/4 Sec. 33 T6N R5W T7N R6W

3. OWNER AT TIME OF DRILLING Sebastian Bros.

4. OWNER'S COMPLETE MAIL ADDRESS R1 Prairie du Chienn

5. Distance in feet from well to nearest:
 (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C. I.	TILE	SEWER CONNECTED	C. I.
			INDEPENDENT	TILE
	30'	60'		60'

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	80'		85'		150'	150'		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	240	6	240	550	Clay	Surface	10
						limestone	10	115

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	new black steel plain ends 19.18	Surface	240	sandstone	115	190
				Clay	190	215
				limestone	215	460
				sandstone	460	550

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	10
Cement	10	240

Well construction completed on Jan 2 1969

11. MISCELLANEOUS DATA
 Yield test: 4 Hrs. at 15 GPM
 Well is terminated 10 inches above below final grade

Depth from surface to normal water level 460 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 467 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 1-6-1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Denneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
481				