

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 29 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Bridgeport

2. LOCATION 1/4 Section NW Section 34 Township 6N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Lester Olson

OR - Grid or Street No. Street Name T7N? ADDRESS R7D

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, WI 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 35' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Sewage Sump Clearwater Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 60'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|------------|------------|----------|------------|------------|----------|
| 10 | Surface | 202 | 6 | 202 | 380 |

9. FORMATIONS

| Kind | From (ft.) | To (ft.) |
|----------------|------------|----------|
| Clay | Surface | 8 |
| limestone | 8 | 70 |
| soft sandstone | 70 | 185 |
| limestone | 185 | 380 |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification & Method of Assembly | From (ft.) | To (ft.) |
|------------|---|------------|----------|
| 6 | new black steel P.E. 18.97 A-53 Valley Steel Pitted adaptor | Surface | 202 |

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|--------|------------|----------|
| Clay | Surface | 8 |
| Cement | 8 | 202 |

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air Reverse Rotary

Rotary-w/drilling mud

Well construction completed on 8-16-1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 290 Ft.

Depth of water level when pumping 312 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-24-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Kopion Registered Well Driller Complete Mail Address Boscobel, WI R3 Box 84 53805