

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

SEP 11 1973

file original as sec. 34, copy as sec. 35

36702

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Bridgeport

2. LOCATION - 1/4 Section SE Section 34 Township 6N Range 6W 3. OWNER AT TIME OF DRILLING Gaylord Matti

OR - Grid or street no. OT Sec 35?? Street name T7N ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE		
<u>15'</u>	<u>30'</u>	<u>30'</u>		

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>50'</u>			<u>70'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>184</u>	<u>6</u>	<u>184</u>	<u>400</u>	<u>Clay</u>		<u>Surface</u>	<u>15</u>
						<u>limestone</u>		<u>15</u>	<u>50</u>
						<u>soft shale &amp; mixed clay</u>		<u>50</u>	<u>100</u>
						<u>soft sandstone</u>		<u>100</u>	<u>160</u>
						<u>limestone</u>		<u>160</u>	<u>380</u>
						<u>sandstone</u>		<u>380</u>	<u>400</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>184</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>184</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 8-31- 19 73

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM

Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 290 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 312 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 9-6- 19 73

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Roscoke, Wis. 53805  
R.3 Box 84

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
----------------------	---------------	---------------	-----------	---------

487