

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie du Chien
 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Villa Louis [C. N/2, N 1/2, SW 1/4, Sec 25, T 7 N, R 7 W]

3. OWNER AT TIME OF DRILLING Wis. Historical Society
 4. OWNER'S COMPLETE MAIL ADDRESS Madison

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER		FLOOR DRAIN		FOUNDATION DRAIN		WASTE WATER DRAIN	
	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT	C. I.	TILE
100	-	-	-	-	-	-	-	-

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PFT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE	
								C. I.	TILE
-	-	-	-	-	-	-	-	-	-

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
 -

6. Well is intended to supply water for: Institution

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
16	Surface	160				Gravel with sand	Surface	45
8	160	271				Course gravel	45	49
6	271	375				sand	49	105

8. CASING, LINER, CURBING, AND SCREEN				
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	
8	New Ductile C.I. + C - 28.6	+2 Surface	160	Gravel with sand
4	New " " " 12.9	+4	271	Mag. lime Med. shale
				tan clay sand

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
cement	Surface	271

11. MISCELLANEOUS DATA

Yield test: 12 Hrs. at 20 GPM

Well construction completed on 6-28 1968

Well is terminated 4 ft inches above below final grade

Depth from surface to normal water level artesian flowing ft. Well disinfected upon completion Yes No

Depth to water level when pumping +2 ft. Well sealed watertight upon completion Yes No

Water sample sent to laboratory on: No Record 1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Rolph J. Fabry Registered Well Driller COMPLETE MAIL ADDRESS Platteville

COLIFORM TEST RESULT GAS - 24 HRS. GAS - 48 HRS. CONFIRMED 9/4/70 CC REMARKS M.E. Ostrom

495

Please do not write in space below