

MAR 30 1983

1. COUNTY Crawford		CHECK (✓) ONE: <input type="checkbox"/> Town <input type="checkbox"/> Village <input checked="" type="checkbox"/> City Prairie Du Chien		Name CR-191	
2. LOCATION OR - Grid or Street No. NE, SW, NW Section 25 Township 7N Range 7W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE State Historical Society of WI		ADDRESS Bureau of Facilities Management (Agent) Villa Louis	
AND - If available subdivision name, lot & block No.		POST OFFICE Prairie Du Chien, WI		ZIP CODE 53821	
4. Distance in feet from well to nearest: (Record answer in appropriate block) 200		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		C.I.		C.I. Sewer	
		Other		Other Sewer	
		C.I.		C.I.	
		Other		Other	
		C.I.		C.I.	
		Other		Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm C.I. Other		Sewer		Sewage Sump	
		Clearwater Dr.		Clearwater Sump	
				Clearwater Sump	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Well	
				Pump	
				Tank	
				Subsurface Pumproom	
				Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
				Earthen Manure Basin	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Manure Storage Basin	
				Concrete Floor Only	
				Concrete Floor and Partial Concrete Walls	
				Other (Describe)	
5. Well is intended to supply water for: Drinking Water and Pond		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		Sand + gravel		Surface 118	
10 Surface 250		Sandstone		118 375	
6 250 375					
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification					
Dia. (in.) Mfg. & Method of Assembly		From (ft.)		To (ft.)	
10 New Standard 36 5 wall Steel 40.48 lbs per foot		Surface		118	
6 New Standard Steel .280 wall 18.97 lbs per foot		+ 4		250	
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)		To (ft.)	
neat cement		Surface		250	
11. MISCELLANEOUS DATA					
Yield Test: _____ Hrs. at _____ GPM		Artesian well 25		Well construction completed on June 25, 1974	
Depth from surface to normal water level _____ Ft.		Well is terminated 4 inches		<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth of water level when pumping _____ Ft. Stabilized <input type="checkbox"/> Yes <input type="checkbox"/> No		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to Madison by R. Gaszodar laboratory on _____ 19____					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
496 Signature R. Gaszodar		Business Name and Complete Mailing Address 578 Water Ave. Hillsboro, WI			
Registered Well Driller					