

JUL 17 1972

12062

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section NW Section 1 Township 8N Range 3W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Windward Farms
ADDRESS R7D
POST OFFICE Boscobel, Wis. 53805

4. Distance in feet from well to nearest:
(Record answer in appropriate block) 1 mile

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE

CLEAR WATER DRAIN C.I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Cattle in pasture

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>156</u>	<u>6</u>	<u>156</u>	<u>440</u>	<u>Clay</u>	<u>Surface</u>	<u>30</u>
						<u>Clay & stone</u>	<u>30</u>	<u>65</u>
						<u>limestone</u>	<u>65</u>	<u>170</u>
						<u>sandstone</u>	<u>170</u>	<u>280</u>
						<u>hard shale stone</u>	<u>280</u>	<u>400</u>
						<u>sandstone</u>	<u>400</u>	<u>440</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>30</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>30</u>	<u>156</u>	Well construction completed on <u>7-5-1972</u>		

11. MISCELLANEOUS DATA			Well is terminated	
Yield test:	<u>10</u> Hrs. at	<u>5</u> GPM	<u>12</u> inches	<input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	<u>380</u> ft.		Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>382</u> ft.		Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 7-12-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>498</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				