

AUG 10 1982

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Bridgeport

2. LOCATION SE, SE Section 4 Township 6N Range 2W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Frank Weeks

OR - Grid or Street No. R6W Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Platte Duchien ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 300' Sanitary Bldg. Drain C.I. Sanitary Bldg. Sewer C.I. Floor Drain Connected To: C.I. Sewer Storm Bldg. Drain C.I. Storm Bldg. Sewer C.I.

Street Sewer San. Other Sewers Other Foundation Drain Connected to: Sewer Sewage Sump C.I. Clearwater Sump Clearwater Dr. Septic Tank 330' Holding Tank 330' Sewage Absorption Unit Seepage Pit Manure Hopper or Retention or Pneumatic Tank Seepage Bed 300' Seepage Trench

Privy Pit Pet Waste Pit Well Pit: Nonconforming Existing Nonconforming Existing Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

Well is intended to supply water for: home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)		From (ft.)		To (ft.)		Kind	From (ft.)	To (ft.)
10		Surface		42'6"		St. Peter Clay Sand	Surface	23'
6		42'6"		364'		St. Peter Sandstone	23'	30'
						Mag. Lime	30'	238'

7. CASING, LINER, CURBING AND SCREEN			
Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	New Star Tec 1945 A-53 youngstown	Surface	42'6"

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	42'6"

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 4-29 1982

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 30 GPM Well is terminated 8 inches above final grade below

Depth from surface to normal water level 270' Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 280' Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Aug 2 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J Fabert Registered Well Driller Business Name and Complete Mailing Address Faberly Drilling Co. Inc.
120 Broadway
Platteville, WI