

MAR 31 1980

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City				Name Marietta	
2. LOCATION OR - Grid or Street No. Street Name SE 9 T8N		Township T8N		Range 3 W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Howard Chapman	
AND - If available subdivision name, lot & block No.				ADDRESS RFD.			
				POST OFFICE Boscobel, WI 53805			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 50'		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer		Storm Bldg. Drain C.I. Other	
		Storm Bldg. Sewer C.I. Other		Storm Bldg. Sewer C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump		Sewage Sump C.I. Other	
				Clearwater Sump		Septic Tank 200'	
				Holding Tank		Sewage Absorption Unit 150' Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing		Barn Gutter 50'	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)	
5. Well is intended to supply water for: farm home				9. FORMATIONS			
6. DRILLHOLE				Kind			
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				From (ft.) To (ft.)			
10 Surface 70 6 70 100				Clay Surface 10			
				Clay & sand 10 50			
				Hard shalestone 50 80			
				sandstone 80 100			
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly				Dia. (in.) From (ft.) To (ft.)			
6 new black steel PE 18.97				Surface 70			
A-53							
Keystone Pipe							
Pitless Adapter							
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)				<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with			
Clay Surface 8				<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air			
Cement 8 70				<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water			
				Well construction completed on 3-15 1980			
11. MISCELLANEOUS DATA				Yield Test: 4 Hrs. at 6 GPM			
Depth from surface to normal water level 60 Ft.				Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth of water level when pumping 72 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to Madison laboratory on 3-24 1980				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

Signature
Philip S. Caplan
Registered Well Driller

Complete Mail Address
Rt. 2 Box 4 Boscobel, WI 53805