

FEB 27 1978

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION % Section <u>NW</u> Section <u>29</u> Township <u>7N</u> Range <u>3W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Virgil Pittsley</u>		ADDRESS <u>R1 Box 116</u>	
OR - Grid or Street No. Street Name <u>(8)</u>		POST OFFICE <u>Boscobel, Wis., 53805</u>		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>10'</u>		Building		Sanitary Bldg. Drain	
		C.I. Other		Sanitary Bldg. Sewer	
		C.I. Other		Floor Drain Connected To:	
				Storm Bldg. Drain	
				Storm Bldg. Sewer	
				C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit <u>75'</u>	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pumproom	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Country home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
<u>10</u> <u>Surface</u> <u>0</u> <u>49</u> <u>6</u> <u>49</u> <u>100</u>			<u>Clay & loose stone</u> <u>Surface</u> <u>0</u> <u>30</u>		
			<u>sandstone</u> <u>30</u> <u>57</u>		
			<u>limestone</u> <u>57</u> <u>80</u>		
			<u>sandstone</u> <u>80</u> <u>100</u>		
7. CASING, LINER, CURBING AND SCREEN					
Dia. (in.) Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
<u>6</u> <u>new black steel</u> <u>P.E. 18.97</u> <u>A-53</u>			<u>Surface</u> <u>0</u> <u>49</u>		
<u>Valley Steel</u>					
<u>Pitless adapter</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.) To (ft.)		
<u>Clay</u> <u>Surface</u> <u>0</u> <u>7</u>			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<u>Cement</u> <u>7</u> <u>49</u>			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
			Well construction completed on <u>1-30-1978</u>		
11. MISCELLANEOUS DATA			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <u>53</u> Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>58</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>2-21-1978</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>520 Kenneth Coplan</u> Registered Well Driller			Complete Mail Address <u>R3 Box 84 Boscobel, Wis. 53805</u>		