

APR 18 1974

APR 24 1974

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY: Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - Section NW Section 1 Township T8N Range R4W 3. OWNER AT TIME OF DRILLING James Cooper

OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
(Record answer in appropriate block) C.I. TILE C.I. TILE SEWER CONNECTED INDEPENDENT C.I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C.I. TILE 60

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	Surface	<u>170</u>				<u>Clay</u>	Surface	<u>5</u>
<u>6</u>	<u>170</u>	<u>520</u>				<u>St. Peter Sandstone</u>	<u>5</u>	<u>60</u>
						<u>Mag Limestone</u>	<u>60</u>	<u>300</u>
						<u>Cambrian Sandstone</u>	<u>300</u>	<u>445</u>
						<u>Limestone</u>	<u>445</u>	<u>470</u>
						<u>Sandstone</u>	<u>470</u>	<u>520</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>New Steel T&C</u>	<u>19.18</u>	<u>170</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>170</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on Aug 25 1973

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 15 GPM

Depth from surface to normal water level 380 ft.

Depth to water level when pumping 420 ft.

Well is terminated 8 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 4/8 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph J. Faherty Registered Well Driller COMPLETE MAIL ADDRESS FAHERTY DRILLING CO., INC.
1120 Broadway
PLATTEVILLE, WISCONSIN 53818

COLIFORM TEST RESULT 527 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71