

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
N. W. Part of Sec. 9 T8N R4-W

3. OWNER AT TIME OF DRILLING Mrs. Dove Barton

4. OWNER'S COMPLETE MAIL ADDRESS R7D Steuben, Wis., 54657

5. Distance in feet from well to nearest:

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE		
60'	50'				50'			
CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	70'		80'		125'	125'		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	111	6	111	160	Clay	Surface	80
						soft sandstone	80	100
						hard sandstone	100	160

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new - black - plain ends 19.18	Surface	111

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	80
Cement	80	111

11. MISCELLANEOUS DATA	
Yield test: <u>6</u> Hrs. at <u>18</u> GPM	Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level <u>100</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping <u>110</u> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <u>Madison, Wis.</u>	laboratory on: <u>5-6-</u> <u>1968</u>

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Kopin Registered Well Driller COMPLETE MAIL ADDRESS 53805 R3 Box 84 Boscobel, Wis.

Please do not write in space below

COLIFORM TEST RESULT	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
545				